© CONTEC





* Specifications, color and design of the products are subject to change without notice.

Features

The input range is common to different channels, and can be selected from four input ranges, including unipolar and bipolar ranges.

The ability to accommodate differential input permits the accurate measurement of voltage values over long distances from the signal source and even under a considerable potential difference.

A rotary switch allows you to set device IDs to help you keep track of device numbers.

The system incorporates a screwless connector plug that allows you to easily attach and detach wires without using any special tools.

Similar to other F&eIT series products, the system, in the module itself, incorporates a 35-mm DIN rail mounting mechanism as a standard item. A connection to a controller module can be effected on a lateral, stack basis in a unique configuration, which permits a simple, smart system configuration without the need for a backplane board.

Congratulations on your recent purchase of an Insulator Digital Input Module.

By converting external analog voltage signals into digital data, this product can process them inside the F&eIT series controller module < CPU-CAxx(FIT)GYGY, CPU-SBxx(FIT)GY etc >. The insulation between external signals and the Controller Module permits the use of the Controller Module without compromising the communications features of the latter.

Specification

Specifications

Item	Specifications	
Analog input section		
Input format	Bus-isolated voltage input	
Input range	Bipolar ±10V, ±5V Unipolar 0 - 10V, 0 - 5V	
Maximum input voltage	±20V	
Input impedance	1MΩ□(Min.)	
Input channel	Differential input, 8 channels	
Resolution	12-bit	
Non-linear error *1	±3LSB	
Conversion rate	Number of conversion channels x 10µsec + 20µsec	
Data buffer	8-Word	
Interrupt	Either IRQ5 or IRQ7 or IRQ9 *2	
Internal sampling timer	10µsec - 1,073,741,824µsec *3	
Common section		
Internal power	5VDC±5% 350mA (Max.)	
consumption		
Maximum distance of	1.5m	
signal extension		
External dimensions (mm)	25.2 (W) x 64.7 (D) x 94.0 (H) (exclusive of protrusions)	
Weight (module itself)	100g	
Module connection	Stack connection by the connector that is provided with the side	
method	of module	
Module installation method	One-touch connection to 35mm DIN rails	
	(standard connection mechanism provided in the system)	
Applicable wire	AWG 28 - 20	
Applicable plug	FK- MC 0,5/12-ST-2,5 (made by Phoenix Contact Corp.)	
*1 When the environment	temperature is near 0°C or 50°C, the non-linearity error may	

become larger.

*2 Available only when this product is connected to the CPU-SBxx(FIT)GY.
*3 When this product is connected to the ADI12-8(USB)GY, the sampling timer built in the ADI12-8(USB)GY is used. The setting range is from 1,000 - 1,073,741,824µsec.

A CAUTION

When connecting one of the modules to a controller module, the internal power consumption should be taken into account. If the total current exceeds the capacity of the power supply unit, the integrity of the operation cannot be guaranteed. For further details, please see the Controller Module manual.

Depending upon the specific controller module that is used, some of the functions are not supported.

ADI12-8(FIT)GY

1

© CONTEC

Installation Environment Requirements

Parameter		Requirement description
Operating temperature		0 - 50°C
Storage temperature		-10 - 60°C
Humidity		10 - 90% RH (No condensation)
Floating dust particles		Not to be excessive
Corrosive gases		None
Line- Noise	Line-noise	AC line/2kV, Signal line/1kV (IEC1000-4-4Level 3, EN61000-4-4Level 3)
resistance	Static electricity resistance	Contact discharge/4kV (IEC1000-4-2Level 2, EN61000-4-2Level 2) Atmospheric discharge/8kV (IEC1000-4-2Level 3, EN61000-4-2Level 3)
Vibration resistance	Sweep resistance	10 - 57Hz/semi-amplitude 0.15mm, 57 - 150Hz/2.0G 80minutes each in X, Y, and Z directions (JIS C0040-compliant, IEC68-2-6-compliant)
Impact res	istance	15G, half-sine shock for 11ms in X, Y, and Z directions (JIS C004-compliant, IEC68-2-27-compliant)
Certification		FCC Class A, VCCI Class A, CE Marking (EMC Directive Class A, RoHS Directive) LIKCA

Packing List

Module ...1 First Step Guide ...1 CD-ROM [F&eIT Series Setup Disk] *1...1 Interface connector plugs ...2 Warranty Certificate...1 Serial number label...1

*1 The CD-ROM contains various software and User's Manual.



How to Connect an Interface Connector

When connecting the Module to an external device, you can use the supplied connector plug. When wiring the Module, strip off approximately 7 - 8 mm of the covering for the cable, and insert the bare wire by pressing the orange button on the connector plug. Releasing the orange button after the wire is inserted to fix the cable. Compatible wires are AWG 28 - 20.



▲ CAUTION

Removing the connector plug by grasping the cable can break the wire.

Signal Layout on the Interface Connector

The Module can be connected to an external device using a 12pin (1 group) connector that is provided on the Module face.



Setting a Device ID

The controller module distinguishes and keeps track of the modules that are connected to it by assigning device IDs to them. Each module, therefore, should be assigned a unique ID.

A Device ID can be assigned in a 0 - 7 range, so that a maximum of eight modules can be distinguished.

To connect this product to the ADI12-8(USB)GY, assign a device ID between 1 and 3.

The factory setting for the Device ID is [0].

Setup Method

A device ID can be set by turning the rotary switch on the device face.

To set a device ID, turn the switch knob.



Block Diagram



3